



NOTES:

- 1) MINIMUM PIPE BEDDING SHALL BE AS FOLLOWS:  
 4" FOR PIPE 12" IN DIAMETER OR LESS  
 6" FOR PIPE 15" TO 36" IN DIAMETER  
 8" FOR PIPE 42" IN DIAMETER OR GREATER

CITY OF CORVALLIS

ENGINEERING DIVISION

TRENCH BACKFILL &  
PIPE ZONE DETAIL

DATE: JANUARY, 2003

SCALE: NONE

STANDARD DETAIL No.

APPROVED:

*[Signature]*

201